County of Modoc
Building and Safety Department
Modoc County is a collaborative community where people, families, government, and businesses, live, work, and thrive.

DECLARATION OF INSTALLATION
SMOKE DETECTORS AND CARBON MONOXIDE DETECTORS *(10-23-2024)*

Scott Ward
Interim Building Official
203 West 4th St.
Alturas, CA 96101
Phone: 530-6413
Email:
scottward@co.modoc.ca.us

Building Permit # _____

Project Address: _____

Dear Property Owner or Licensed Contractor: The California Residential Code (CRC) requires that carbon monoxide (CO) alarms as well as smoke alarms shall be installed in dwelling units intended for human occupancy upon application for a permit for alterations, repairs, or additions exceeding one thousand dollars ($1,000). In order to grant a final approval on your permit, it is necessary to verify the installation of these alarms within your dwelling unit. This form provides you the ability to self-verify this installation to Development Services staff when convenient access to the interior of the dwelling is not readily available, (e.g., re-roof, rooftop photovoltaic system, service change or other exterior work).

DECLARATION OF INSTALLATION UNDER THE PENALTY OF PERJURY

By signing this document as the owner or licensed contractor, I/we affirm and declare under the penalty of perjury, under the laws of the State of California, by our signatures below as owner or licensed contractor that I/we will comply prior to final inspection with Items A & B as specified herein and in accordance with CRC sections R314 and R315 :

A. Smoke alarms are installed in accordance with the approved manufacturer's instructions and per the requirements of the California Residential Code, in all of the following areas: a. Each sleeping room(s). b. Outside each separate sleeping area in the immediate vicinity of the bedrooms. c. On each additional story of the dwelling, including basements and habitable attics d. Smoke alarms shall be installed not less than 3 feet (914 mm) horizontally from the door or opening of a bathroom that contains a bathtub or shower unless this would prevent placement of a smoke alarm required by this section.

B. Carbon Monoxide alarms are installed in accordance with the approved manufacturer's instructions and per the requirements of the California Residential Code, in dwelling units where either the dwelling unit contains a fuel-fired appliance or fireplace and/or the dwelling unit has an attached garage with an opening that communicates with the dwelling unit. a. Outside of each separate sleeping area in the immediate vicinity of the bedrooms b. On every occupiable level of dwelling unit, including basements. c. Where a fuel-burning appliance is located within a bedroom or its attached bathroom, a carbon monoxide alarm shall be installed within the bedroom.

Owner's name(print): _____

Owner's signature: _____ Date: _____

Contractor's name (print): _____ CSLB License # _____

Contractor's signature: _____ Date: _____